



WAWA DRINKING WATER SYSTEM

Annual and Summary Report 2022

Wawa 
Real algoma.

Prepared by:


Water & Sewer Department
Infrastructure Services

March 2023

WAWA DRINKING WATER SYSTEM

Annual and Summary Report 2022

Prepared by: Municipality of Wawa
Infrastructure Services
Water & Sewer Department



Rebecca Weatherall, P. Eng – Assistant
Director, Infrastructure Services
David Lowe – Water and Wastewater Operator
Josée Parisé – Water and Wastewater Operator

March 15/23
Date

**Reviewed
by:**



Daniel Beach, CRS – Director,
Infrastructure Services

MARCH 15/23
Date

Presented to Council: March 21, 2023
Date

**Presentation Confirmed
by Resolution:** _____
Date

Table of Contents

1.0	Introduction.....	1
1.1	Requirements of the Summary Report.....	1
1.2	Background.....	1
1.3	Facility Specifics.....	1
1.4	Format.....	1
2.0	System Requirements	2
2.1	The Act and Regulations.....	2
2.2	Operational Checks, Sampling and Testing	3
3.0	System Performance.....	7

Tables

Table 1:	Annual Summary of Operational Checks for 2021	4
Table 2:	Summary of Annual Lead Testing under Schedule 15.1.....	5
Table 3:	Maximum Raw Water and Finished Water Flows	7
Table 4:	Summary of Annual Flows and Water Consumption	8

Appendices

Appendix A:	Definition of Terms
Appendix B:	Wawa Drinking Water System 2022 Annual Report
Appendix C:	Certificate of Accreditation for a Full Scope of the Drinking Water Quality Management System (DWQMS)
Appendix D:	Wawa Water Treatment Plant Inspection Report

1.0 Introduction

1.1 Requirements of the Summary Report

The 2022 Annual and Summary Report for the Municipality of Wawa Drinking Water System (DWS) are being submitted to satisfy both Section 11 and Schedule 22 of the Ontario Regulation 170/03. The requirements of the regulation for each report have been consolidated into a single document. This report is intended to brief the owner and the consumers of the Wawa Drinking Water System on the system's performance over the past calendar year January 1 to December 31, 2022.

This report encompasses all elements as required by O. Reg. 170/03. Each section explains what is required for the category Large Municipal Residential DWS (as it pertains to the Wawa DWS), how limits were met and if shortfalls were revealed.

1.2 Background

The Wawa water supply system serves the Community of Wawa– sometimes referred to as the Wawa townsite and the Michipicoten River Village– which are located within the Municipality of Wawa, District of Algoma. The facility is owned, maintained and operated by The Corporation of the Municipality of Wawa and serves approximately 3,000 people. There are no major industrial users in the community.

The Wawa Water Treatment Plant (WTP) is located at 40C Broadway Avenue, at the north-east corner of Ganley Street and McKinley Avenue. The plant was constructed in accordance with Certificate of Approval 7008-648JTL issued by the Ministry of the Environment, Conservation and Parks (MECP) and remedied the deficiencies of the original plant. The WTP includes a low lift pumping station, membrane filtration system, disinfection utilizing sodium hypochlorite, fluoridation using hydrofluosilicic acid, chlorine contact cells, treated water storage, high lift pumping and a standby generator. The WTP has a rated capacity of 7,880 m³/day.

1.3 Facility Specifics

- The Wawa Water Treatment Plant is a Class II Plant. This type of facility requires the Overall Responsible Operator (ORO) to have a Class II Operator License. Due to staffing shortages, Kresin Engineering Corp. is the Municipality's designated ORO. The Water and Wastewater Lead Hand possess a Class II Water Treatment License and a Class II Water Distribution License.
- Maximum rate of Raw Water Taking: 25,000 m³/day
- Waterworks Number: 210000050

1.4 Format

Chapter 2 of this report deals with the performance of the system and compliance with the requirements of the Act, Regulations, the system's approval, drinking water works permit, municipal drinking water license and any orders applicable to the system that were not met at any time during the period covered by the report.

Chapter 3 presents conclusions of the performance of the system.

2.0 System Requirements

2.1 The Act and Regulations

2.1.1 General

The system was compliant with the Act and Regulations during 2022.

2.1.2 Municipal Drinking Water Licence

MUNICIPAL DRINKING WATER LICENCE (2), Licence Number: 231-101, Issued June 07, 2016.

2.1.3 Drinking Water Works Permit

DRINKING WATER WORKS PERMIT (2), Permit Number: 231-201, Issued May 19, 2016.

2.1.4 Permit to take Water

The new Permit to Take Water (PTTW) # 8801-A3ZKAL, which renews, and replaces PTTW #1086-88UQXZ, was issued to The Corporation of the Municipality of Wawa on November 24, 2015.

2.1.5 MECP Inspection Report

The Ministry of Environment, Conservation and Parks (MECP) inspection report outlines the design, operating requirements and observations of the inspector, and includes recommendations and orders where required. Additional items are identified as best practices and serve as a guide to the Municipality and its Operators.

There were no issues regarding non-compliance or additional actions required in 2021.

The results of the 2022 inspection report are pending. The Municipality had not yet received the report when the Annual and Summary Report was submitted to Council. This report shall be amended with the date the inspection report was received and results therein upon receipt of the inspection report. The inspection report will be attached to this document as Appendix D.

2.1.6 Drinking Water Quality Management Standard (DWQMS)

The Drinking Water Quality Management Standard (DWQMS) is a made in Ontario management standard developed specially by the drinking water sector for municipal residential drinking water systems. It is also a tool for Owners and Operators of a drinking system to help ensure that consistent processes and procedures are in place to manage production and delivery of high-quality drinking water.

The development and implementation of the Municipal Drinking Water Licensing Program is based on Justice O'Connor's recommendations in the Walkerton Inquiry Report. A municipal drinking water license is an approval that is issued by the Ministry of the Environment to owners under the Safe Drinking Water Act, 2002 (SDWA) for the operation of municipal residential drinking water systems.

The Municipality of Wawa DWS received their Certificate of Accreditation for a Full Scope Drinking Water Quality Management Standard (DWQMS) renewal on December 12, 2022.

2.2 Operational Checks, Sampling and Testing

2.2.1 Continuous Monitoring Equipment

In accordance with the Drinking Water Works Permit (Issue #2), the Wawa WTP is equipped with continuous monitoring equipment to sample and test for free chlorine residual, turbidity and fluoride concentration in the water leaving the plant. These parameters and others—such as pH—are measured at critical points in the treatment sequence to assist with operational decision making. The data is transmitted to and archived in a designated SCADA system computer in the main control room. The SCADA system analyzes and archives the data to generate daily, monthly and annual reports. Operational set points are programmed into the SCADA system which triggers an auto-dialer if an alarm condition occurs. The auto-dialer notifies Operational Personnel of any potential problems.

2.2.2 Free Chlorine Residual

Free chlorine residual is monitored continuously and recorded every second going into the chlorine contact chambers. This is consistent with the requirements in Schedule 7 of Regulation 170/03 that indicated that "...sampling and testing for free chlorine residual is carried out by continuous monitoring equipment in the treatment process at or near a location where the intended contact time has just been completed in accordance with the Ministry Procedure for Disinfection of Drinking Water in Ontario."

Chlorine residual readings of the water entering the clear wells for the year was averaged at 1.02 mg/L and for water being pumped to the distribution system was averaged at of 0.87 mg/L. Refer to Table 1 for the minimum and maximum.

2.2.3 Turbidity

At the Wawa Water Treatment Plant, turbidity is continuously monitored in the effluent from each of the three membrane filter skids and recorded every second, consistent with Regulation 170/03. From January 1 to December 31, 2022 the average turbidity from all three skids was 0.04 NTU.

The Ministry Procedure for Disinfection of Drinking Water in Ontario further requires that filtered water turbidity from membrane filtration processes be less than or equal to 0.10 NTU in 95% of the measurements each month in order to claim 2.0 + log cryptosporidium removal credit. Information from the operations at the plant indicates that this condition was met.

The turbidity for the water being pumped to distribution is also monitored and recorded every second. From January 1 to December 31, 2022, the average was 0.04 NTU. Refer to Table 1 below for the minimum and maximum.

2.2.4 Fluoride

At the Wawa Water Treatment Plant, fluoride is continuously monitored in the discharge from the high lift pumps and recorded at one second intervals. The average of the concentration recorded for the period of January 1 to December 31, 2022 was 0.66 mg/L. Regulation 170/03 (Schedule 7, sub.7.4) only requires fluoride testing once every day.

As per Ontario regulation 169/03 for Ontario Drinking Water Quality Standards the Maximum Allowable Concentration for fluoride is 1.5 mg/L for systems that provide fluoridation and if you have an exceedance of the Maximum Allowable Concentration, it is to be treated as an indicator of adverse water quality and must be reported to the proper authorities. There were no fluoride adverse incidents. Refer to Table 1 below for the minimum and maximum.

Table 1: Annual Summary of Operational Checks for 2022

Parameter	Number of Samples	Minimum	Average	Maximum
Free Chlorine Residual Entering CT Chamber (mg/L)	Online Analyzer (sample every second)	0.29	1.02	5.04
Free Chlorine Residual Pumped to the Distribution System (mg/L)	Online Analyzer (sample every second)	0.21	0.87	5.00
Turbidity Effluent from Each of the Three Membrane Filter Skids (NTU)	Online Analyzer (sample every second)	0.02	0.04	1.30
Fluoride Residual Pumped to the Distribution System (mg/L)	Online Analyzer (sample every second)	0.39	0.66	1.85
Distribution System Turbidity (NTU)	Online Analyzer (sample every second)	0.00	0.04	9.99

Note: The minimum and maximum residuals do not show true; there are the “spikes” in the readings that are caused by routine maintenance on analyzers (turning power off and back on). After maintenance, Operations Staff complete grab samples to calibrate the unit. This method has been discussed with and accepted by the Ministry of the Environment, Conservation and Parks.

2.2.5 Microbiological Sampling and Testing

The Regulation requires that:

1. In the distribution system, a minimum of twelve samples must be taken monthly and tested for:
 - E-Coli;
 - Total Coliforms; and
 - HPC (25% of the samples tested for this).

At least one of these samples must be taken every week.

2. Treated water samples at the Wawa WTP are to be taken at least once every week and tested for:
 - E-Coli or Fecal Coliform;

- Total Coliforms; and
 - HPC.
3. Raw water samples at the WTP are to be taken at least once every week and tested for:
- E-Coli; and,
 - Total Coliform.

Testing has conformed to the requirements of Regulation 170/03.

2.2.6 Chemical Testing

In accordance with Ontario Regulation 170/03, Schedule 13 – Chemical Sampling and Testing, for Large Municipal Residential System with surface water supply, the following testing is to be performed annually:

- Schedule 23 – Inorganic parameters;
- Schedule 24 – Organic parameters; and
- Lead – new mandatory testing since December 2007 – of testing for lead in the distribution system and into household plumbing. Refer to Table 2 on the for results from the 2022 lead sampling in the Municipality.

Table 2: Summary of Annual Lead Testing under Schedule 15.1

	Number of Samples	Range of Lead Results (min # - max #)	Number of Exceedances
Plumbing	N/A	N/A	N/A
Distribution	4	<1.0 - 2.4	0

Note: As per the Amended Reg.170/03 (Drinking Water System) made under the Safe Drinking Water Act, 2002, the Community Lead Testing Program (Schedule 15.1) The Municipality of Wawa is now exempt from plumbing sampling for lead. As per Drinking Water System Regulation 170/03, made under the Safe Drinking water Act 2002, schedule 15.1-4 subsection 10.

In accordance with Ontario Regulation 170/03, Schedule 13 – Chemical Sampling and Testing, for Large Municipal Residential System with surface water supply, the following testing is to be performed quarterly:

- THM;
- HAA; and
- Nitrates and Nitrites.

In accordance with Ontario Regulation 170/03, Schedule 13 – Chemical Sampling and Testing, for Large Municipal Residential System with surface water supply, the following testing is to be performed every 60 months:

- Sodium

A review of the Municipality's records confirmed that all testing was performed as required during this reporting period. There was one adverse water sampling result in October 2022. Algoma Public Health and the Spills Action Center were notified, and staff followed direction provided by Algoma Public Health which resulted in resampling upstream of and again at the adverse result sampling location. Results from resampling indicated that the original adverse sample was a faulty sample and that no additional measures needed to be taken.

In 2014, the annual average for THMs in the Municipality's drinking water was 112.9 µg/L, exceeding the current allowable concentration of 100 µg/L. This does not pose any short-term or acute health risk. However, the Algoma Public Health Unit issued a drinking water advisory (DWA) for the whole Municipality on November 26, 2014. As a result of the efforts taken by the Municipality to reduce the THM concentration, the DWA from The Algoma Public Health Unit was lifted on June 10, 2020. The average THM concentration in 2022 was 63.50 µg/L.

THMs are formed as a by-product predominantly when chlorine is used to disinfect water for drinking. They represent one group of chemicals generally referred to as disinfection by-products. They result from the reaction of chlorine or bromine with organic matter present in the water being treated.

In addition, the Ontario Drinking Water Standard for Haloacetic Acids (HAAs) came into effect January 1, 2020, the standard is 80.0 µg/L. The Municipality's average for 2022 was 47.38 µg/L.

Furthermore, the Municipality began a monitoring testing plan in August 2019 as per the June 2019 inspection report's summary recommendations and best practice issues. In 2022, the Municipality sampled seasonally (July to October) raw and treated water, with the average Microcystin (Blue /Green Algae) at a level of <0.1 µg/L, well below the maximum acceptable concentration of 1.5 µg/L.

The Municipality of Wawa was also selected by the MECP to participate in a Drinking Water Surveillance Program (DWSP). This program is voluntary and no cost to the Municipality. Samples are routinely taken and sent to the MECP lab in Etobicoke, Ontario for analysis. The Operators consider this program to be another beneficial resource for monitoring water quality for the Municipality.

3.0 System Performance

The Wawa WTP flows are monitored continuously in the raw water intake and discharge to the distribution system, and are recorded on the SCADA system. Daily reports are generated that indicate the minimum, average, maximum and total monthly, and yearly flow. Table 3 illustrates the monthly maximum raw water and finished water flows, and Table 4 summarizes the plants annual flows and water consumption for 2022.

Table 3: Maximum Raw Water and Finished Water Flows

Month	Maximum Raw Water Taking Flow (m³/d)	Maximum Finished Water to Distribution System Flow (m³/d)
January	3,535.80	3,157.70
February	3,793.60	3,088.20
March	3,775.10	3,214.30
April	3,859.40	3,750.70
May	3,406.40	2,904.20
June	3,074.50	2,667.00
July	2,658.00	2,305.10
August	4,547.30	3,801.10
September	2,649.80	2,050.10
October	2,325.00	1,863.00
November	2,704.60	2,261.70
December	3,313.50	2,660.70
Maximum Allowable Daily Volume	25,000.00	7,880.00
Highest % of Maximum Volume	18%	48%

Table 4: Summary of Annual Flows and Water Consumption

Month	Total Consumption (m³)	Average Daily Flow (m³/d)	Maximum Daily Flow (m³/d)	Instantaneous Peak Flow (L/s)	Wawa Monthly Consumption (m³)	Net MRV Monthly Consumption (m³)
January	81,092.70	2,615.90	3,157.70	46.00	79,127.70	1,965.00
February	73,812.50	2,636.10	3,088.20	78.80	72,150.50	1,662.00
March	88,795.60	2,864.40	3,214.30	56.10	86,253.60	2,542.00
April	80,310.00	2,677.00	3,750.70	70.80	78,125.00	2,185.00
May	75,042.10	2,421.00	2,904.20	50.30	72,790.10	2,252.00
June	59,716.50	1,990.50	2,667.00	83.70	57,852.50	1,864.00
July	51,897.50	1,674.10	2,305.10	89.50	50,267.50	1,630.00
August	56,241.30	1,814.20	3,801.10	68.80	54,553.30	1,688.00
September	58,481.70	1,949.39	2,050.10	117.00	57,018.70	1,463.00
October	51,226.30	1,750.10	1,863.00	40.70	49,611.30	1,615.00
November	50,199.40	1,945.70	2,261.70	46.50	49,137.40	1,062.00
December	60,754.80	2,377.40	2,660.70	39.80	59,224.80	1,530.00
Annual Totals	Total Consumption (m³)	Average Daily Flow (m³/d)	Maximum Daily Flow (m³/d)	Maximum Peak Flow (m³/d)	Wawa Total Consumption (m³)	MRV Total Consumption (m³)
	787,570.40	2,226.32	3,801.10	117.00	766,112.40	21,458.00

The Wawa Water Treatment Plant has an approved, rated treatment capacity of 7,880 m³/day which includes an allowance of 392 m³/day to serve Michipicoten River Village. The maximum day flow in 2022 was 3,801.10 m³/day, which is approximately 48.2% of the WTP total rated capacity. The maximum recorded instantaneous flow rate was 117.0 L/s that occurred during the month of September.

Appendix A

Definition of Terms

AWQI	Adverse water quality incident
CT value	Product of disinfectant concentration and contact time (mg-min/L)
DWS	Drinking water system
EC	E. Coli
HAA	Haloacetic acids
HPC	Heterotrophic plate count
MAC	Maximum Acceptable Concentration
MECP	Ministry of the Environment, Conservation and Parks
m³	Cubic metres
m³/d	Cubic metres per day
mg/L	Milligram per litre (part per million)
ML	Megalitre (1000 m ³)
NTU	Nephelometric turbidity unit
ODWS	Ontario Drinking Water Standards
O. Reg. 170/03	Ontario Regulation 170/03
PLC	Programmable logic controller
PTTW	Permit to take water
SCADA	Supervisory control and data acquisition
TC	Total coliforms
THM	Trihalomethane
µg/L	Microgram per litre (part per billion)
WD	Water distribution
WT	Water treatment

Appendix B

WAWA DRINKING WATER SYSTEM

Waterworks No. 210000050



**Annual Report
2022**

WAWA WATER SYSTEM 2020 ANNUAL REPORT

Drinking-Water System Number:	210000050
Drinking-Water System Name:	Wawa Water Supply System
Drinking-Water System Owner:	The Corporation of the Municipality of Wawa
Drinking-Water System Category:	Municipal Residential – Large
Period being reported:	01-01-21 to 31-12-21

<p><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></p> <p>Does your Drinking-Water System serve more than 10,000 people? Yes [] No [X]</p> <p>Is your annual report available to the public at no charge on a web site on the Internet? Yes [X] No []</p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p> <table border="1" style="width: 100%;"> <tr><td>Municipal Office</td></tr> <tr><td>40 Broadway Avenue</td></tr> <tr><td>Wawa, Ontario</td></tr> <tr><td>POS 1K0</td></tr> </table>	Municipal Office	40 Broadway Avenue	Wawa, Ontario	POS 1K0	<p><u>Complete for all other Categories.</u></p> <p>Number of Designated Facilities served:</p> <p align="center">N/A</p> <p>Did you provide a copy of your annual report to all Designated Facilities you serve? Yes [] No [X]</p> <p>Number of Interested Authorities you report to:</p> <p align="center">N/A</p> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes [] No [X]</p>
Municipal Office					
40 Broadway Avenue					
Wawa, Ontario					
POS 1K0					

Note: For the following tables below, additional rows or columns may be added or an appendix may be attached to the report

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:

Drinking Water System Name	Drinking Water System Number
- - - NONE - - -	

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?

Yes [] No [X]

Indicate how you notified system users that your annual report is available, and is free of charge.

Public access/notice via the web

Public access/notice via Government Office

Public access/notice via a newspaper

Public access/notice via Public Request

Public access/notice via a Public Library

Public access/notice via other method

Describe your Drinking-Water System

Water Treatment Plant consisting of a membrane filtration process with the intake from Wawa Lake. Raw water is pumped through the membrane filters then chlorinated before going to an under-floor reservoir. Sodium hypochlorite is used for pre-chlorination, primary and secondary disinfection, and membrane cleaning. Hydrofluorosilicic acid is added to filtered water before entering the under-floor reservoir. (In 2020, the addition of aluminum sulphate to the raw water was initiated on July 15, 2020, to reduce THMs (Trihalomethanes) in the drinking water. Aluminum sulphate (Alum) is used as a coagulant to reduce organic matter in the water. With alum added, organic matter combines to form particles large enough to be removed from the water during filtration and before sodium hypochlorite addition (chlorine). With reduced levels of organic matter in the water, less chlorine is required and in-turn, less THMs and other disinfection by-products (like haloacetic acids, HAAs) are formed. Water quality analysis results from samples collected in the water treatment plant and in the water distribution system confirmed a reduction in THMs, HAAs and chlorine demand. The need to use alum is anticipated to be on a seasonal basis, when levels of naturally occurring organic matter is greatest. Alum addition ceased in November and the water quality analysis results will be reviewed to help confirm appropriate start and stop dates for 2023.

Residue from the filter backwash and acid cleaning can be discharged to the municipal sanitary sewer system or to the storm sewer system. Continuous analyzers are in place for turbidity, chlorine residual and fluoride monitoring. Flow meters are used to monitor raw water flow into each filter train and treated and chlorinated water entering the under-floor reservoir.

A transmission main connects the Wawa water distribution system to the elevated water storage tank at the Michipicoten River Village, where a "touch-up" chlorination facility using sodium hypochlorite is installed.

List all water treatment chemicals used over this reporting period

- Sodium hypochlorite
- Hydrofluorosilicic acid
- Aluminum Sulphate (seasonally)

Were any significant expenses incurred to?

- Install required equipment
- Repair required equipment
- Replace required equipment
- Maintenance

Please provide a brief description and a breakdown of monetary expenses incurred

- No additional capital expenses were incurred during 2022

Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre

<i>Incident Date</i>	<i>Parameter</i>	<i>Result</i>	<i>Unit of Measure</i>	<i>Corrective Action</i>	<i>Corrective Action Date</i>

Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.

	Number of Samples	Range of E.Coli or Fecal Results (min #)-(max #)	Range of Total Coliform Results (min #)-(max #)	Number of HPC Samples	Range of HPC Results (min #)-(max #)
Raw	52	0 – 4	0 - 176	N - A	N – A
Treated	52	Absent	Absent	52	0 – 1
Distribution	212	Absent	Absent	53	0 – 4

An additional distribution system sample was required this year for an adverse result at the Water Tower. The additional sample was taken as per directions provided by Algoma Public Health and results indicated that there was no adverse water entering the water tower.

**Operational testing done under Schedule 7, 8 or 9 of
Regulation 170/03 during the period covered by this Annual Report.**

Water Treatment Plant

	Number of Grab Samples	Minimum	Average	Maximum
Turbidity (NTU)	8760	0.00	0.045	1.300
Chlorine (mg/l)	8760	0.209	0.869	5.000
Fluoride (mg/l)	8760	0.390	0.664	1.850

NOTE: For continuous monitors use 8760 as the number of samples.

Note: Minimum and Maximum levels are caused by instrument spikes due to maintenance to the instruments.

Distribution System

	Number of Samples	Minimum	Average	Maximum
Chlorine Residual (mg/l)	365	0.62	0.78	2.01

Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.

Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure
Certificate of Approval 7805-76ZKUC	Waste Water Suspended Solids	N/A	None	No Discharge
Certificate of Approval 7805-76ZKUC	Waste Water Chlorine Residual	N/A	None	No Discharge

Summary of Inorganic parameters tested during this reporting period or the most recent sample results

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony	18-Jan-22	<0.60	µg/L	No
Arsenic	18-Jan-22	<1.0	µg/L	No
Barium	18-Jan-22	<10	µg/L	No
Boron	18-Jan-22	<50	µg/L	No
Cadmium	18-Jan-22	<0.10	µg/L	No
Chromium	18-Jan-22	<1.0	µg/L	No
Fluoride	18-Jan-22	0.425	µg/L	No
*Lead				
Mercury	18-Jan-22	<0.10	µg/L	No
Nitrate	18-Jan-22	0.042	µg/L	No
Nitrite	18-Jan-22	<0.010	µg/L	No

Selenium	18-Jan-22	<1.0	µg/L	No
Sodium	18-Jan-22	6.91	µg/L	No
Uranium	18-Jan-22	<2.0	µg/L	No

Note: Only for drinking water systems testing under Schedule 15.2; this includes large municipal non-residential systems, small municipal non-residential systems, non-municipal seasonal residential systems, large non-municipal non-residential systems, and small non-municipal non-residential systems

Summary of lead testing under Schedule 15.1 during this reporting period

(Applicable to the following drinking water systems; large municipal residential systems, small municipal residential systems, and non-municipal year-round residential systems)

Note: The Municipality of Wawa is now exempt from plumbing sampling for lead. As per Drinking water System Regulation 170/03, made under the Safe Drinking water Act 2002, schedule 15.1-4 subsection 10.

Location Type	Number of Samples	Range of Lead Results (min#) – (max #)	Number of Exceedances
Plumbing	N/A	N/A	N/A
Distribution	4	<1.0 – 2.4	0

Summary of Organic parameters sampled during this reporting period or the most recent sample results

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	18-Jan-22	<0.10	µg/L	No
Aldicarb				
Aldrin + Deildrin				
Atrazine + N-dealkylated metabolites	18-Jan-22	<0.20	µg/L	No
Azinphos-methyl	18-Jan-22	<0.10	µg/L	No
Bendiocarb				
Benzene	18-Jan-22	<0.50	µg/L	No
Benzo(a)pyrene	18-Jan-22	<0.005	µg/L	No
Bromoxynil	18-Jan-22	<0.20	µg/L	No
Carbaryl	18-Jan-22	<0.20	µg/L	No
Carbofuran	18-Jan-22	<0.20	µg/L	No
Carbon Tetrachloride	18-Jan-22	<0.20	µg/L	No
Chlordane (Total)				
Chlorpyrifos	18-Jan-22	<0.10	µg/L	No
Cyanazine				
Diazinon	18-Jan-22	<0.10	µg/L	No
Dicamba	18-Jan-22	<0.20	µg/L	No

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
1,2-Dichlorobenzene	18-Jan-22	<0.50	µg/L	No
1,4-Dichlorobenzene	18-Jan-22	<0.50	µg/L	No
Dichlorodiphenyltrichloroethane (DDT) + metabolites				
1,2-Dichloroethane	18-Jan-22	<0.50	µg/L	No
1,1-Dichloroethylene (Vinylidene Chloride)	18-Jan-22	<0.50	µg/L	No
Dichloromethane	18-Jan-22	<5.0	µg/L	No
2-4 Dichlorophenol	18-Jan-22	<0.30	µg/L	No
2,4-Dichlorophenoxy acetic acid (2,4-D)	18-Jan-22	<0.20	µg/L	No
Diclofop-methyl	18-Jan-22	<0.20	µg/L	No
Dimethoate	18-Jan-22	<0.10	µg/L	No
Dinoseb	18-Jan-22	<0.20	µg/L	No
Diquat	18-Jan-22	<1.0	µg/L	No
Diuron	18-Jan-22	<1.0	µg/L	No
Glyphosate	18-Jan-22	<5.0	µg/L	No
Haptachlor + Heptachlor Epoxide				
Lindane (Total)				
Malathion	18-Jan-22	<0.10	µg/L	No
Methoxychlor				
Metolachlor	18-Jan-22	<0.10	µg/L	No
Metribuzin	18-Jan-22	<0.10	µg/L	No
Monochlorobenzene	18-Jan-22	<0.50	µg/L	No
Paraquat	18-Jan-22	<1.0	µg/L	No
Parathion				
Pentachlorophenol	18-Jan-22	<0.50	µg/L	No
Phorate	18-Jan-22	<0.10	µg/L	No
Picloram	18-Jan-22	<0.20	µg/L	No
Polychlorinated Biphenyls (PCB)	18-Jan-22	<0.035	µg/L	No
Prometryne	18-Jan-22	<0.10	µg/L	No
Simazine	18-Jan-22	<0.10	µg/L	No
THM (See latest annual average)				
Temephos				
Terbufos	18-Jan-22	<0.20	µg/L	No
Tetrachloroethylene	18-Jan-22	<0.50	µg/L	No
2,3,4,6-Trichlorophenol	18-Jan-22	<0.50	µg/L	No
Triallate	18-Jan-22	<0.10	µg/L	No
Trichloroethylene	18-Jan-22	<0.50	µg/L	No
2,4,6-Trichlorophenol	18-Jan-22	<0.50	µg/L	No
2,4,6-Trichlorophenoxy acetic acid (2,4,5-T)				

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Trifluralin	18-Jan-22	<0.10	µg/L	No
Vinyl Chloride	18-Jan-22	<0.20	µg/L	No

THM – Summary Table

Date of Test	Location	Results (µg/L)
18-Jan-22	Mission Tower	74.5
04-Apr-22	Mission Tower	70.5
12-Jul-22	Mission Tower	74.3
27-Jul-22	Mission Tower	73.5
09-Aug-23	Mission Tower	73.8
23-Aug-22	Water Tower	58.3
06-Sep-22	Water Tower	55.6
20-Sep-22	Water Tower	64.4
11-Oct-22	End of Distribution	55
01-Nov-22	End of Distribution	53
15-Nov-22	Water Tower	45.9
02-Dec-22	Water Tower	44.1
12-Dec-22	Water Tower	82.6

Average THM's for the year 2022 was 63.50 µg/L with the maximum acceptable concentration of 100 µg/L (A). "A" – The standard for THM's is expressed as a running annual average.

HAA – Summary Table

Date of Test	Location	Results (µg/L)
18-Jan-22	3 Chris Simon Drive	48.8
04-Apr-22	3 Chris Simon Drive	47.7
12-Jul-22	3 Chris Simon Drive	61.4
11-Oct-22	3 Chris Simon Drive	31.6

Average HAA's for the year 2022 was 44.70 µg/L with the maximum acceptable concentration of 80 µg/L (A). "A" – The standard for HAA's is expressed as a running annual average.

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample

Appendix C

Drinking Water Quality Management Standard

Certificate of Accreditation



CERTIFICATE OF ACCREDITATION

This is to certify that the following operating authority:

Municipality of Wawa

40 Broadway Avenue, Wawa, Ontario P0S 1K0 Canada

Refer to Attachment to Certificate of Accreditation dated December 12, 2022 for additional drinking water systems

operates a

Quality Management System

which conforms with the requirements of

DRINKING WATER QUALITY MANAGEMENT STANDARD VERSION 2 - 2017

for the following scope of accreditation

Full Scope - Entire DWQMS

Certificate No.: CERT-0148753
File No.: 1633210
Issue Date: December 12, 2022

Original Certification Date: December 17, 2013
Certification Effective Date: December 14, 2022

Calin Moldovean
President, Business Assurance
SAI Global Assurance



DWQMS 2017



ATTACHMENT TO CERTIFICATE OF ACCREDITATION

These sites are accredited under Certificate No: CERT-0148753 issued on December 12, 2022

File No.

1633210

Municipality of Wawa

40 Broadway Avenue, Wawa, Ontario P0S 1K0 Canada

Effective Date

December 14, 2022

Drinking Water Systems

	Site No.	Site Name
Yes	1633211	Wawa Drinking Water System

These accreditations are dependent on Municipality of Wawa (File No. 1633210) maintaining their scope of registration to DRINKING WATER QUALITY MANAGEMENT STANDARD VERSION 2 - 2017

Appendix D

Ministry of the Environment, Conservation and Parks

Wawa Drinking Water System
Inspection Report and Inspection Rating